

## SECTION 15820 - DUCT ACCESSORIES

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. This Section includes the following:
  - 1. Manual-volume dampers.
  - 2. Backdraft dampers.
  - 3. Fire and smoke dampers.
  - 4. Turning vanes.
  - 5. Duct-mounted access doors and panels.
  - 6. Flexible ducts.
  - 7. Flexible connectors.
  - 8. Duct humidifiers.
  - 9. Duct accessory hardware.
- B. Related Sections include the following:
  - 1. Division 15 Section "Air Terminals" for constant-volume and variable-air-volume control boxes, and reheat boxes.
  - 2. Division 15 Section "Diffusers, Registers, and Grilles."
  - 3. Division 15 Section "Control Systems Equipment" for electric and pneumatic damper actuators.
  - 4. Division 16 Section "Fire Alarm Systems" for duct-mounted fire and smoke detectors.

#### 1.3 SUBMITTALS

---



- 
- A. Product Data: For the following:
1. Manual-volume dampers.
  2. Backdraft dampers.
  3. Fire and smoke dampers.
  4. Duct-mounted access doors and panels.
  5. Flexible ducts.
  6. Duct Humidifiers
- B. Shop Drawings: Detail equipment assemblies and indicate dimensions, weights, loadings, required clearances, method of field assembly, components, location, and size of each field connection. Detail the following:
1. Special fittings and manual- and automatic-volume-damper installations.
  2. Fire- and smoke-damper installations, including sleeves and duct-mounted access doors and panels.
  3. Duct humidifier configuration.
- C. Product Certificates: Submit certified test data on dynamic insertion loss; self-noise power levels; and airflow performance data, static-pressure loss, dimensions, and weights.

#### 1.4 QUALITY ASSURANCE

- A. NFPA Compliance: Comply with the following NFPA standards:
1. NFPA 90A, "Installation of Air Conditioning and Ventilating Systems."
  2. NFPA 90B, "Installation of Warm Air Heating and Air Conditioning Systems."

#### 1.5 EXTRA MATERIALS

- A. Furnish extra materials described below that match products installed, are packaged with protective covering for storage, and are identified with labels describing contents.

- 
1. Fusible Links: Furnish quantity equal to 10 percent of amount installed.

## PART 2 - PRODUCTS

### 2.1 SHEET METAL MATERIALS

- A. Galvanized, Sheet Steel: Lock-forming quality; ASTM A 653/A 653M, **G90 (Z275)** coating designation; mill-phosphatized finish for surfaces of ducts exposed to view.
- B. Carbon-Steel Sheets: ASTM A 366/A 366M, cold-rolled sheets, commercial quality, with oiled, exposed matte finish.
- C. Aluminum Sheets: **ASTM B 209 (ASTM B 209M)**, Alloy 3003, Temper H14, sheet form; with standard, one-side bright finish for ducts exposed to view and mill finish for concealed ducts.
- D. Extruded Aluminum: **ASTM B 221 (ASTM B 221M)**, Alloy 6063, Temper T6.
- E. Reinforcement Shapes and Plates: Galvanized steel reinforcement where installed on galvanized, sheet metal ducts; compatible materials for aluminum and stainless-steel ducts.
- F. Tie Rods: Galvanized steel, **1/4-inch (6-mm)** minimum diameter for **36-inch (900-mm)** length or less; **3/8-inch (10-mm)** minimum diameter for lengths longer than **36 inches (900 mm)**.

### 2.2 BACKDRAFT DAMPERS

- A. Description: Suitable for horizontal or vertical installations.
- B. Frame: **0.052-inch- (1.3-mm-)** thick, galvanized, sheet steel, with welded corners and mounting flange.
- C. Blades: **0.050-inch- (1.2-mm-)** thick aluminum sheet.

- D. Blade Seals: Neoprene.
- E. Blade Axles: Galvanized steel.
- F. Tie Bars and Brackets: Galvanized steel.
- G. Return Spring: Adjustable tension.

## 2.3 MANUAL-VOLUME DAMPERS

- A. General: Factory fabricated with required hardware and accessories. Stiffen damper blades for stability. Include locking device to hold single-blade dampers in a fixed position without vibration. Close duct penetrations for damper components to seal duct consistent with pressure class.
  - 1. Pressure Classifications of 3-Inch wg (750 Pa) or Higher: End bearings or other seals for ducts with axles full length of damper blades and bearings at both ends of operating shaft.
- B. Standard Volume Dampers: Multiple- or single-blade, parallel- or opposed-blade design as indicated, standard leakage rating, with linkage outside air-stream, and suitable for horizontal or vertical applications.
  - 1. Steel Frames: Hat-shaped, galvanized, sheet steel channels, minimum of 0.064 inch (1.62 mm) thick, with mitered and welded corners; frames with flanges where indicated for attaching to walls; and flangeless frames where indicated for installing in ducts.
  - 2. Roll-Formed Steel Blades: 0.064-inch- (1.62-mm-) thick, galvanized, sheet steel.
  - 3. Blade Axles: Galvanized steel.
  - 4. Tie Bars and Brackets: Galvanized steel.
- C. Low-Leakage Volume Dampers: Multiple- or single-blade, parallel- or opposed-blade design as indicated, low-leakage rating, with linkage outside air-stream, and suitable for horizontal or vertical applications.

- 
1. Steel Frames: Hat-shaped, galvanized, sheet steel channels, minimum of 0.064 inch (1.62 mm) thick, with mitered and welded corners; frames with flanges where indicated for attaching to walls; and flangeless frames where indicated for installing in ducts.
  2. Roll-Formed Steel Blades: 0.064-inch- (1.62-mm-) thick, galvanized, sheet steel.
  3. Blade Seals: Neoprene.
  4. Blade Axles: Galvanized steel.
  5. Tie Bars and Brackets: Galvanized steel.
- D. Jackshaft: 1-inch- (25-mm-) diameter, galvanized steel pipe rotating within a pipe-bearing assembly mounted on supports at each mullion and at each end of multiple-damper assemblies.
1. Length and Number of Mountings: Appropriate to connect linkage of each damper of a multiple-damper assembly.
- E. Damper Hardware: Zinc-plated, die-cast core with dial and handle made of 3/32-inch- (2.4-mm-) thick zinc-plated steel, and a 3/4-inch (19-mm) hexagon locking nut. Include center hole to suit damper operating-rod size. Include elevated platform for insulated duct mounting.

## 2.4 FIRE DAMPERS

- A. General: Labeled to UL 555.
- B. Fire Rating: One and one-half hours.
- C. Frame: SMACNA Type B with blades out of airstream; fabricated with roll-formed, 0.034-inch- (0.85-mm-) thick galvanized steel; with mitered and interlocking corners.
- D. Mounting Sleeve: Factory- or field-installed galvanized, sheet steel.
  1. Minimum Thickness: 0.052 inch (1.3 mm) or 0.138 inch (3.5 mm) thick as indicated, and length to suit application.

2. Exceptions: Omit sleeve where damper frame width permits direct attachment of perimeter mounting angles on each side of wall or floor, and thickness of damper frame complies with sleeve requirements.

- E. Mounting Orientation: Vertical or horizontal as indicated.
- F. Blades: Roll-formed, interlocking, 0.034-inch- (0.85-mm-) thick, galvanized, sheet steel. In place of interlocking blades, use full-length, 0.034-inch- (0.85-mm-) thick, galvanized steel blade connectors.
- G. Horizontal Dampers: Include a blade lock and stainless-steel negator closure spring.
- H. Fusible Link: Replaceable, 212 deg F (100 deg C) rated.

## 2.5 SMOKE DAMPERS

- A. General: Labeled to UL 555S. Combination fire and smoke dampers shall be labeled for one-and-one-half-hour rating to UL 555.
- B. Fusible Link: Replaceable, 212 deg F (100 deg C) rated as indicated.
- C. Frame and Blades: 0.064-inch- (1.62-mm-) thick, galvanized, sheet steel.
- D. Mounting Sleeve: Factory-installed, 0.052-inch- (1.3-mm-) thick, galvanized, sheet steel; length to suit wall or floor application.
- E. Damper Motors: Provide for modulating or two-position action.
  1. Permanent-Split-Capacitor or Shaded-Pole Motors: With oil-immersed and sealed gear trains.
  2. Spring-Return Motors: Equip with an integral spiral-spring mechanism where indicated. Enclose entire spring mechanism in a removable housing designed for service or adjustments. Size for running torque rating of 150 in. x lbf (17 N x m) and breakaway torque rating of 150 in. x lbf (17 N x m).
3. Modulating, Spring-Return Motor: 115 V, single phase, 60 Hz.

---

## 2.6 TURNING VANES

- A. Fabricate to comply with SMACNA's "HVAC Duct Construction Standards-- Metal and Flexible."
- B. Manufactured Turning Vanes: Fabricate of 1-1/2-inch- (38-mm-) wide, curved blades set 3/4 inch (19 mm) o.c.; support with bars perpendicular to blades set 2 inches (50 mm) o.c.; and set into side strips suitable for mounting in ducts.

## 2.7 DUCT-MOUNTED ACCESS DOORS AND PANELS

- A. General: Fabricate doors and panels airtight and suitable for duct pressure class.
- B. Frame: Galvanized, sheet steel, with bend-over tabs and foam gaskets.
- C. Door: Double-wall, galvanized, sheet metal construction with insulation fill and thickness, and number of hinges and locks as indicated for duct pressure class. Include vision panel where indicated. Include 1-by-1-inch (25-by-25-mm) butt or piano hinge and cam latches.
- D. Seal around frame attachment to duct and door to frame with neoprene or foam rubber.
- E. Insulation: 1-inch- (25-mm-) thick, fibrous-glass or polystyrene-foam board.

## 2.8 FLEXIBLE CONNECTORS

- A. General: Flame-retarded or noncombustible fabrics, coatings, and adhesives complying with UL 181, Class 1.
- B. Standard Metal-Edged Connectors: Factory fabricated with a strip of fabric 3-1/2 inches (89 mm) wide attached to two strips of 2-3/4-inch- (70-mm-) wide, 0.028-inch- (0.7-mm-) thick, galvanized, sheet steel or 0.032-inch (0.8-mm) aluminum sheets. Select metal compatible with connected ducts.

## 2.9 FLEXIBLE DUCTS

- A. General: Comply with UL 181, Class 1.
- B. Flexible Ducts, Insulated: Factory-fabricated, insulated, round duct, with an outer jacket enclosing 1-1/2-inch- (38-mm-) thick, glass-fiber insulation around a continuous inner liner.
  - 1. Reinforcement: Steel-wire helix encapsulated in inner liner.
  - 2. Outer Jacket: Glass-reinforced, silver Mylar with a continuous hanging tab, integral fibrous-glass tape, and nylon hanging cord.
- C. Pressure Rating: 4-inch wg (1500 Pa) positive for ducts upstream of VAV boxes, 1/2-inch wg (125 Pa) all others.

## 2.10 DUCT HUMIDIFIERS

- A. General: Multiple tube duct mounted steam humidifier
- B. Water steam separator: Centrifugal type stainless steel.
- C. Dispersion tubes:
  - 1. Designed to provide proportional distribution of steam across entire length of dispersion tube
  - 2. Jacketed by steam at supply pressure
  - 3. Stainless steel
  - 4. Dispersion tube shall extend across width of duct.
- D. Modulation Control Valve: Normally closed modulating parabolic plug type valve with stainless steel plug and seat and having modified linear flow characteristics. Valve to be furnished with electric actuator for stable operation over entire valve stroke. Valve shall be tested and in full compliance with ANSI B16.15 class 250 pressure/temperature ratings, ANSI B16.104 class IV control valve shut off leakage and ISAS75.11 flow characteristics standard.



- 
- E. Steam Trap: Humidifier shall be furnished with float and thermostatic traps. A steam supply line strainer shall also be provided.

## 2.11 ACCESSORY HARDWARE

- A. Instrument Test Holes: Cast iron or cast aluminum to suit duct material, including screw cap and gasket. Size to allow insertion of pitot tube and other testing instruments, and length to suit duct insulation thickness.
- B. Flexible Duct Clamps: Stainless-steel band with cadmium-plated hex screw to tighten band with a worm-gear action, in sizes 3 to 18 inches (75 to 450 mm) to suit duct size.
- C. Adhesives: High strength, quick setting, neoprene based, waterproof, and resistant to gasoline and grease.

## PART 3 - EXECUTION

### 3.1 INSTALLATION

- A. Install duct accessories according to applicable details shown in SMACNA's "HVAC Duct Construction Standards--Metal and Flexible" for metal ducts and NAIMA's "Fibrous Glass Duct Construction Standards" for fibrous-glass ducts.
- B. Install volume dampers in lined duct; avoid damage to and erosion of duct liner.
- C. Provide test holes at fan inlet and outlet and elsewhere as indicated.
- D. Install fire and smoke dampers according to manufacturer's UL-approved written instructions.
  - 1. Install fusible links in fire dampers.
- E. Install duct humidifiers per manufacturer's instructions and as shown on drawings.

1. Install downstream of filter banks
  2. Allow sufficient distance between humidifier and elbows (or other obstruction) to prevent wetting.
- F. Install duct access panels downstream from volume dampers, fire dampers, turning vanes, and equipment.
1. Install duct access panels to allow access to interior of ducts for cleaning, inspecting, adjusting, and maintaining accessories and terminal units.
  2. Install access panels on side of duct where adequate clearance is available.
- G. Label access doors according to Division 15 Section "Mechanical Identification."

### 3.2 ADJUSTING

- A. Adjust duct accessories for proper settings.
- B. Adjust fire and smoke dampers for proper action.
- C. Final positioning of manual-volume dampers is specified in Division 15 Section "Testing, Adjusting, and Balancing."

END OF SECTION 15820